



## RFI #1

**Job Name:** CC – Lawton, OK

**Reason:** Concrete Foundations

**Date Submitted:** 1/17/2023

**Attn:** David Adamski & Kyle Bruns

**Request:**

Should there be column foundations at the short walls at column lines 1 & 7?

If so, would these be column foundations type F4?

**Response:** They are not required on the transverse walls of the building. A small area of enlarged grade beam is provided. Confirmed with structural.

---

---

---

---

**Responder's Signature:**

**Printed Name:** Kyle A. Bruns

**Date:** 2023-01-17